

# Final Report 206180



## Laboratory Services

**Delivery Address:** Sydney Water Corporation  
51 Hermitage Rd  
West Ryde NSW 2114

**Analysis contact:** Tel : (02) 9800 6935  
**Email:** [analyticalservices@sydneywater.com.au](mailto:analyticalservices@sydneywater.com.au)

**Issue Date:** 3/07/2019

**Issued By :** Matthew Vernon  
Commercial Client

**Supersedes Report No.:** 206050

**Attention:** Victor Papierniak-Wojtowicz  
**Customer:** Cobar Shire Council  
**Customer ID:** ZCSC

**Address:** PO Box 223  
Cobar NSW 2835  
**Telephone:** 6835 5800

**Email:** [victor.papierniak@cobar.nsw.gov.au](mailto:victor.papierniak@cobar.nsw.gov.au)

### CONTENTS

1. Sydney Water Approved Signatory
2. Sample Summary
3. Analytical results
4. Comments
5. Laboratory QC results

### Sydney Water Approved Signatory

Jeya Gajendran, Clean & Waste Water Analyst  
Greta Haddad, Nutrients Laboratory Supervisor

Jouliet Ashak, Microbiology Analyst



Where a result is required to meet a compliance limit or specification the associated uncertainty must be considered. Uncertainty estimates are available for all accredited test results.

**Corporate Accreditation No 63**

**Accredited for compliance with ISO/IEC 17025 - Testing**

**SAMPLE SUMMARY**

<u>Client Sample ID</u>	<u>Sample Number</u>	<u>Sampling Procedure</u>	<u>Date Sampled</u>	<u>Date Received</u>	<u>Date Authorised</u>	<u>Description</u>
Point 1	L19049238	1	17/06/2019	18/06/2019	27/06/2019	Polisher
Point 2	L19049239	1	17/06/2019	18/06/2019	27/06/2019	Turkeys
Point 3	L19049240	1	17/06/2019	18/06/2019	27/06/2019	Inlet STW
Point 5	L19049242	1	17/06/2019	18/06/2019	27/06/2019	Outlet of Mml Aerator

**Sampling procedures**

- 1 Samples analysed as received.
- 2 Samples collected as per FS procedures SAWI 070, Excluding Oil & Grease which is collected as per clients instructions.
- 3 Samples collected as per FS procedures SAWI 070.
- 4 Results reported as received from WNSW.

**ANALYTICAL RESULTS**

<b>Client Sample ID</b>		Point 1	Point 2	Point 3	Point 5				
<b>Sampled Date</b>		17/06/2019 08:15:00 AM	17/06/2019 08:23:00 AM	17/06/2019 08:30:00 AM	17/06/2019 08:30:00 AM				
<b>Sample Number</b>		L19049238	L19049239	L19049240	L19049242				
<b>CHEMISTRY</b>									
<b>WC12MET : Conductivity</b>									
Conductivity (uS/cm)	uS/cm	1107	1073	-	-				
Date of Performance	DD/MM/YY	18/06/19	18/06/19						
<b>WC17NS : Biological oxygen demand</b>									
BOD5	mg/L	<2	<2	87	27				
Date of Performance	DD/MM/YY	19/06/19	19/06/19	19/06/19	19/06/19				
<b>WC26NS500 : Grease</b>									
Oil & Grease	mg/L	<5	<5	-	-				
Date of Performance	DD/MM/YY	20/06/19	20/06/19						
<b>WC44NS : Determination of Total, Fixed &amp; Volatile Suspended Solids</b>									
Total Suspended Solids	mg/L	4	4	-	-				
Date of Performance	DD/MM/YY	20/06/19	20/06/19						
<b>MICRO</b>									

"-" = Not required or refer to Laboratory comment

Client Sample ID		Point 1	Point 2	Point 3	Point 5				
<b>Sampled Date</b>		17/06/2019 08:15:00 AM	17/06/2019 08:23:00 AM	17/06/2019 08:30:00 AM	17/06/2019 08:30:00 AM				
<b>Sample Number</b>		L19049238	L19049239	L19049240	L19049242				
<b>MICRO</b>									
MI01MUG : Faecal Coliform and/or E. coli									
E.coli	CFU/100mL	-	13	-	-				
Faecal Coliform	CFU/100mL	-	13	-	-				
Date of Performance	D/M/Y H:M		18/06/19 15:08						
<b>NUTRIENTS</b>									
NU102 : Nitrogen & Phosphorus									
Total Nitrogen	mg/L	7.01	4.40	-	-				
Total Phosphorus	mg/L	1.41	0.860	-	-				
Date of Performance	DD/MM/YY	20/06/19	20/06/19						

**COMMENTS**

<u>Sample ID</u>	<u>Comment Level</u>	<u>Method</u>	<u>Test</u>	<u>Comment</u>
L19049239	Method	MI01MUG	-	Result confirmed. Sample analysed outside recommended holding time of 24Hrs.

**Analysis**

MI01MUG

**Analysis Requirements**

Faecal Coliforms and/or E.Coli: all results are presumptive unless indicated otherwise.

"- " = Not required or refer to Laboratory comment

**LABORATORY QC RESULTS**

N/A - Not Applicable

PQL - Practical Quantitation Limit

LOQ - Limit of Quantification

RPD - Relative Percent Difference

SPIKE/Positive Control - Addition of a known amount and concentration

Duplicate Precision = Accepted - Result 2 within 95% confidence limits of result 1

Duplicate Precision = Outlier - Result 2 outside 95% confidence limits of result 1

Duplicate Precision = Not calculated - Result is outside test range

LOQ	Blank	Positive Control <i>Acceptance Criteria</i>	Negative Control <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	Precision <i>Acceptance Criteria</i>
<b>MI01MUG [Membrane Filtration]E.coli</b>						
<1 CFU/100mL	<1	Accepted	Accepted	13	9	Accepted
<b>MI01MUG [Membrane Filtration]Faecal Coliform</b>						
<1 CFU/100mL	<1	Accepted	Accepted	13	9	Accepted

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
<b>NU102 Total Nitrogen</b>						
<0.05 mg/L	<0.05	0.90 <i>0.88 - 1.12 mg/L</i>	106 % Recovery <i>80 - 120 % Recovery</i>	0.27	0.29	B <i>0 - 0 %</i>
<b>NU102 Total Phosphorus</b>						
<0.002 mg/L	<0.002	0.051 <i>0.045 - 0.055 mg/L</i>	98 % Recovery <i>80 - 120 % Recovery</i>	0.020	0.021	B <i>0 - 50 %</i>
<b>WC12MET Conductivity (uS/cm)</b>						
<1 uS/cm	F	1410 <i>1393 - 1433 uS/cm</i>	E			
<b>WC17NS BOD5</b>						
<2 mg/L	<2	190 <i>139 - 257 mg/L</i>	E	87	91	4.49 % <i>0 - 20 %</i>

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
<b>WC26NS500 Oil &amp; Grease</b>						
<5 mg/L	<5	<b>89</b> 85.1 - 101.5 mg/L	<b>E</b>			
<b>WC44NS Total Suspended Solids</b>						
<2 mg/L	<2	<b>48</b> 42.5 - 57.5 mg/L	<b>E</b>	<b>170</b>	<b>170</b>	<b>0.00 %</b> 0 - 20 %

Extra Note:

F: Blank is not applicable for this analyte

B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ

E: Spike is not applicable for this analyte

DUPLICATE Total Phosphorus B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ